

Attachment 2

EXHIBIT "A"

14.08.040 - Private sewage disposal systems.

When connection to the public sewer is not required per Section 14.08.020 a private sewage disposal system may be installed.

- A. Private sewage disposal systems shall comply with the provisions of the City of Hesperia Local Agency Management Program, as may be amended from time to time. The provisions of the City of Hesperia Local Agency Management Program, as amended are incorporated herein by reference with the same force and effect as if the provisions therein were specifically and fully set out herein.
- B. Permits for construction and sizing requirements shall be established by the city using requirements from the California Plumbing Code.
- C. Operation and Maintenance. Private sewage disposal systems shall be operated and maintained in a sanitary manner at all times at no expense to the district.
- D. Connection to Public Sewer. Prior to connection to the public sewer the following shall be completed:
 - 1. The septic tank and seepage pit(s) shall be pumped of all liquids and solids and the pump ticket shall be provided to the city.
 - 2. The bottom of the septic tank shall be broken and inspected by city.
 - 3. The lids for the septic tank and seepage pit(s) shall be removed.
 - 4. The septic tank and seepage pit(s) shall be filled with material approved by the city.
 - 5. When a building or structure is proposed to be placed within the required setbacks of a private sewage disposal system as defined in the California Plumbing Code, the septic tank and/or seepage pit shall be removed entirely.